

County of Santa Clara

Department of Environmental Health

Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



OFFICIAL INSPECTION REPORT

Facility FA0289850 - ALPHA CORNERSTONE ACADEMY PREPARATO	Site Address 1598 LUCRETIA AV, SAN JOSE, CA 95122	Inspection Date 03/20/2024
Program PR0434746 - SCHOOL FOOD SERVICE RISK CAT 2 - FP22	Owner Name ALPHA PUBLIC SCHOOLS	Inspection Time 12:10 - 12:50
Inspected By HENRY LUU	Inspection Type FOLLOW-UP INSPECTION	Consent By FRONT OFFICE

Placard Color & Score

GREEN
N/A

Comments and Observations

Major Violations

Cited On: 02/26/2024

K21 - 8 Points - Hot and cold water not available; 113953(c), 114099.2(b), 114163(a), 114189, 114192, 114192.1, 11419

Compliance of this violation has been verified on: 03/20/2024

Minor Violations

Cited On: 02/26/2024

K06 - 3 Points - Inadequate handwash facilities; supplied or accessible; 113953, 113953.1, 113953.2, 114067(f)

Compliance of this violation has been verified on: 03/20/2024

Cited On: 03/20/2024

K48 - 2 Points - Plan review unapproved; 114380

Inspector Observations: In order to provide hot water to hand wash station and sink, facility has installed an electric tank heater:

Follow-up By
03/27/2024

- State Water Heaters - Electric - 20 gallons - 2000 watt - PCE-20-1OMSA 102

Facility installed new water heater without prior approval from DEH.

[CA] A person proposing to build or remodel a food facility shall submit plans and specifications for review and shall receive plan approval prior to starting any new construction or remodeling. Contact DEH at 408-918-3400 or at www.ehinfo.org to obtain plan check requirements.

- Submit plan check application for addition of single-piece equipment.

***** Submit plans by 3/27/2024

Measured Observations

Item	Location	Measurement	Comments
Hot water	Hand wash sink	110.00 Fahrenheit	
Hot water	One-compartment sink	127.00 Fahrenheit	

Overall Comments:

- On-site for operator requested follow-up inspection to verify compliance of K21 - Hot and cold water available.

- Current follow-up inspection shall be billed at \$290/hour, minimum one hour.

- At time of follow-up inspection, hot water was supplied to all sinks. See measured observations.

- Facility has installed a new tank water heater inside room next to the one-compartment sink. See specifications above on violation.

- Facility has installed new equipment without prior approval from this Division.

- Facility is hereby authorized to resume serving opened food.

- Facility shall submit plan check application for the addition of the water heater. Submit plans by 3/27/2024.

- Failure to submit plans by comply-by date will result in further enforcement action.

- Subsequent follow-up inspection after first follow-up shall be billed \$290/hour, minimum one hour, during normal business hours (Monday - Friday, 7:30 AM to 4:30 PM), and \$629/hour, minimum two hours, during non-business hours, and upon inspector availability.

OFFICIAL INSPECTION REPORT

Facility FA0289850 - ALPHA CORNERSTONE ACADEMY PREPARATO	Site Address 1598 LUCRETIA AV, SAN JOSE, CA 95122	Inspection Date 03/20/2024
Program PR0434746 - SCHOOL FOOD SERVICE RISK CAT 2 - FP22	Owner Name ALPHA PUBLIC SCHOOLS	Inspection Time 12:10 - 12:50

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **4/3/2024**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

Legend:

[CA]	Corrective Action
[COS]	Corrected on Site
[N]	Needs Improvement
[NA]	Not Applicable
[NO]	Not Observed
[PBI]	Performance-based Inspection
[PHF]	Potentially Hazardous Food
[PIC]	Person in Charge
[PPM]	Part per Million
[S]	Satisfactory
[SA]	Suitable Alternative
[TPHC]	Time as a Public Health Control

Received By: Stephanie C.
School operations manager

Signed On: March 20, 2024