

County of Santa Clara

Department of Environmental Health

Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



OFFICIAL INSPECTION REPORT

Facility FA0210031 - KENTUCKY FRIED CHICKEN-552	Site Address 552 E SANTA CLARA ST., SAN JOSE, CA 95112	Inspection Date 07/16/2025
Program PR0301038 - FOOD PREP / FOOD SVC OP 6-25 EMPLOYEES RC 2 - FP13	Owner Name HARMAN-PARLEY, INC.	Inspection Time 17:05 - 17:55
Inspected By ALEXANDER ALFARO	Inspection Type FOLLOW-UP INSPECTION	Consent By BERNICE

Placard Color & Score

GREEN
N/A

Comments and Observations

Major Violations

Cited On: 07/16/2025

K06 - 8 Points - Inadequate handwash facilities: supplied or accessible; 113953, 113953.1, 113953.2, 114067(f)

Compliance of this violation has been verified on: 07/16/2025

Cited On: 07/16/2025

K22 - 8 Points - Sewage and wastewater improperly disposed; 114197

Compliance of this violation has been verified on: 07/16/2025

Minor Violations

N/A

Measured Observations

Item	Location	Measurement	Comments
Water	Restroom hand sink	87.00 Fahrenheit	

Overall Comments:

This is the first follow up inspection where the facility was closed for wastewater overflow/sewage back up.

Observations:

K06:

- There was a roll of paper towels available for use at the front hand sink.
- Per PIC, they are receiving a new dispenser tomorrow.

K21: Water was measured at 87F at the restroom hand sink. Water temperature is no longer adjustable at the handle. Ensure to maintain water temperature between 100-108F.

K22:

- The mop sink is draining and no longer overflowing.
 - The back of house hand sink is draining properly.
 - The front of house hand sink is temporarily inoperable as the waste water pipe is being actively replaced by a plumber.
- Note: There is a hand sink fully stocked and operable in the back of house area.**
- The three compartment sink was draining properly.
 - All floor sinks were draining properly and all toilets were flushing properly.
 - Wastewater overflow/sewage back up has been abated.

K33: The walk in cooler was actively being cleaned out of the ice build up.

K43: The restroom doors were actively having self closing devices installed.

K47: The permit was posted in public view.

Facility is okay to reopen. Provide pictures to district specialist of hand sink being fully repaired with a working dispenser within 24 hours. Failure to provide proof of corrections will result in an additional follow up inspection and subject to any applicable fines.

OFFICIAL INSPECTION REPORT

Facility FA0210031 - KENTUCKY FRIED CHICKEN-552	Site Address 552 E SANTA CLARA ST, SAN JOSE, CA 95112	Inspection Date 07/16/2025
Program PR0301038 - FOOD PREP / FOOD SVC OP 6-25 EMPLOYEES RC 2 - FP13	Owner Name HARMAN-PARLEY, INC.	Inspection Time 17:05 - 17:55

Continue to correct any and all pending violations.

Facility okay to operate.

FACILITY RE-OPENED / PERMIT REINSTATED

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **7/30/2025**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

Legend:

[CA]	Corrective Action
[COS]	Corrected on Site
[N]	Needs Improvement
[NA]	Not Applicable
[NO]	Not Observed
[PBI]	Performance-based Inspection
[PHF]	Potentially Hazardous Food
[PIC]	Person in Charge
[PPM]	Part per Million
[S]	Satisfactory
[SA]	Suitable Alternative
[TPHC]	Time as a Public Health Control



Received By: Bernie
Area Consultant

Signed On: July 16, 2025