

County of Santa Clara

Department of Environmental Health

Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



OFFICIAL INSPECTION REPORT

Facility FA0302951 - UFC GYM SAN JOSE	Site Address 5540 WINFIELD AV 1000, SAN JOSE, CA 95123	Inspection Date 09/27/2024
Program PR0445217 - FOOD PREP / FOOD SVC OP 0-5 EMPLOYEES RC 1 - FP09	Owner Name SJ GYM, LLC	Inspection Time 16:10 - 16:40
Inspected By PRINCESS LAGANA	Inspection Type FOLLOW-UP INSPECTION	Consent By TERRY BRAKE

Placard Color & Score

GREEN
N/A

Comments and Observations

Major Violations

N/A

Minor Violations

Cited On: 09/27/2024

K21 - 3 Points - Hot and cold water not available; 113953(c), 114099.2(b), 114163(a), 114189, 114192, 114192.1, 11419

Inspector Observations: Maximum water temperature at 3 compartment sink measured at 116F.

[CA]: Hot water shall be supplied at a minimum temperature of at least 120°F measured from the faucet throughout facility except at handwash sinks.

Measured Observations

Item	Location	Measurement	Comments
water	hand sink	114.00 Fahrenheit	

Overall Comments:

Follow up inspection regarding closure during routine inspection on 09/25/2024 due to lack of hot water. See minor violation for K-21.

PIC to send Specialist a proof showing at least 120F of hot water at the 3 compartment sink via email at princess.lagana@deh.sccgov.org or via text message at 669-356-2165. Failure to comply may lead to enforcement actions.

FACILITY RE-OPENED / PERMIT REINSTATED

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **10/11/2024**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

Legend:

[CA]	Corrective Action
[COS]	Corrected on Site
[N]	Needs Improvement
[NA]	Not Applicable
[NO]	Not Observed
[PBI]	Performance-based Inspection
[PHF]	Potentially Hazardous Food
[PIC]	Person in Charge
[PPM]	Part per Million
[S]	Satisfactory
[SA]	Suitable Alternative
[TPHC]	Time as a Public Health Control

Received By: Terry Brake
Operations Manager
Signed On: September 27, 2024