

# County of Santa Clara

## Department of Environmental Health

### Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



## OFFICIAL INSPECTION REPORT

Facility FA0276737 - GONG CHA	Site Address 1600 SARATOGA AV 115, SAN JOSE, CA 95129	Inspection Date 05/07/2024
Program PR0418095 - FOOD PREP / FOOD SVC OP 0-5 EMPLOYEES RC 1 - FP09	Owner Name GONG CHA USA	Inspection Time 15:05 - 15:40
Inspected By DENNIS LY	Inspection Type FOLLOW-UP INSPECTION	Consent By SHERRY

Placard Color & Score

**GREEN**  
**N/A**

### Comments and Observations

#### Major Violations

N/A

#### Minor Violations

Cited On: 04/25/2024

K21 - 3 Points - Hot and cold water not available; 113953(c), 114099.2(b), 114163(a), 114189, 114192, 114192.1, 11419

***This violation found not in compliance on 05/07/2024. See details below.***

Cited On: 04/25/2024

K48 - 2 Points - Plan review unapproved; 114380

***This violation found not in compliance on 05/07/2024. See details below.***

#### Measured Observations

N/A

#### Overall Comments:

***Follow-up for routine inspection conducted on 4/25/24 regarding water heater.***

***Water heater was changed to one that is of a smaller capacity and is unable to maintain hot water for in the facility at 120F. Hot water shall be supplied at a minimum temperature of at least 120°F measured from the faucet throughout facility except at handwash sinks.***

***At time of inspection, hot water was ran simultaneously from the three compartment sink and prep sink with temperatures initially measured at 126F but dropped to 86F in under a minute.***

***The addition of new equipment will be required to be submitted to this department's Plan Check for review and approval prior to installation EXCEPT when equipment is replaced like-for-like (same model and capacity as previously approved water heater).***

***A subsequent follow-up inspection will be required and scheduled for 5/21/24.***

***\*\*\*Subsequent follow up inspection after first follow up shall be billed \$290/hr during business hours and \$629/hrs (minimum of 2 hours) during nonbusiness hours upon availability.\*\*\****

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **5/21/2024**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

# OFFICIAL INSPECTION REPORT

Facility FA0276737 - GONG CHA	Site Address 1600 SARATOGA AV 115, SAN JOSE, CA 95129	Inspection Date 05/07/2024
Program PR0418095 - FOOD PREP / FOOD SVC OP 0-5 EMPLOYEES RC 1 - FP09	Owner Name GONG CHA USA	Inspection Time 15:05 - 15:40

## Legend:

[CA]	Corrective Action
[COS]	Corrected on Site
[N]	Needs Improvement
[NA]	Not Applicable
[NO]	Not Observed
[PBI]	Performance-based Inspection
[PHF]	Potentially Hazardous Food
[PIC]	Person in Charge
[PPM]	Part per Million
[S]	Satisfactory
[SA]	Suitable Alternative
[TPHC]	Time as a Public Health Control



Received By: Sherry  
Manager  
Signed On: May 07, 2024