

# County of Santa Clara

## Department of Environmental Health

### Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



## OFFICIAL INSPECTION REPORT

Facility FA0205952 - MCDONALD'S #2888	Site Address 1299 E SANTA CLARA ST, SAN JOSE, CA 95116	Inspection Date 09/03/2025
Program PR0307301 - FOOD PREP / FOOD SVC OP 26+ EMPLOYEES RC 2 - FP16	Owner Name MCDONALD'S CORPORATIO	Inspection Time 17:45 - 18:05
Inspected By ALEXANDER ALFARO	Inspection Type FOLLOW-UP INSPECTION	Consent By SARA

Placard Color & Score <b>GREEN</b> <b>N/A</b>
---

### Comments and Observations

#### Major Violations

Cited On: 09/03/2025

K22 - 8 Points - Sewage and wastewater improperly disposed; 114197

#### Inspector Observations:

**1. Major Violation: The mop sink directly adjacent to the three compartment sink was not draining and was actively filling up when the only three compartment sink is in use.**

*[CA] Food facility shall not operate if there is sewage overflowing or backing up in the food facility. The food facility, or impacted areas, shall remain closed until all plumbing problems have been corrected and all contaminated surfaces have been cleaned and sanitized.*

**2. Minor Violation: Staff were disposing gray water from the mop sink into the first basin of the three compartment sink.**

*[CA] Waste water shall be disposed of in the janitorial sink or toilet facility.*

#### Minor Violations

N/A

#### Measured Observations

Item	Location	Measurement	Comments
Water	Mop Sink	120.00 Fahrenheit	

#### Overall Comments:

***This is the first follow up inspection for the routine inspection where the facility was closed for an active sewage back up. This is also an after business hour inspection and is subject to a \$645 dollar charge.***

#### Observation:

***K22: The mop sink was cleaned out by a plumber and is draining properly. Use of the three compartment sink does not cause the mop sink to back up.***

***Ensure to thoroughly clean and sanitize affected area.***

***Facility is okay to reopen.***

## FACILITY RE-OPENED / PERMIT REINSTATED

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **9/17/2025**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

# OFFICIAL INSPECTION REPORT

<b>Facility</b> FA0205952 - MCDONALD'S #2888	<b>Site Address</b> 1299 E SANTA CLARA ST, SAN JOSE, CA 95116	<b>Inspection Date</b> 09/03/2025
<b>Program</b> PR0307301 - FOOD PREP / FOOD SVC OP 26+ EMPLOYEES RC 2 - FP16	<b>Owner Name</b> MCDONALD'S CORPORATION	<b>Inspection Time</b> 17:45 - 18:05

**Legend:**

- [CA] Corrective Action
- [COS] Corrected on Site
- [N] Needs Improvement
- [NA] Not Applicable
- [NO] Not Observed
- [PBI] Performance-based Inspection
- [PHF] Potentially Hazardous Food
- [PIC] Person in Charge
- [PPM] Part per Million
- [S] Satisfactory
- [SA] Suitable Alternative
- [TPHC] Time as a Public Health Control



---

**Received By:** Sara Portino  
Shift Manager

**Signed On:** September 03, 2025