

County of Santa Clara

Department of Environmental Health

Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



OFFICIAL INSPECTION REPORT

Facility FA0210360 - IMPROV	Site Address 62 S 2ND ST, SAN JOSE, CA 95113	Inspection Date 11/08/2025
Program PR0301115 - FOOD PREP / FOOD SVC OP 6-25 EMPLOYEES RC 2 - FP13	Owner Name SAN JOSE COMEDY CLUB LI	Inspection Time 17:40 - 18:50
Inspected By ALEXANDER ALFARO	Inspection Type FOLLOW-UP INSPECTION	Consent By JULIE

Placard Color & Score

GREEN
N/A

Comments and Observations

Major Violations

Cited On: 11/07/2025

K21 - 8 Points - Hot and cold water not available; 113953(c), 114099.2(b), 114163(a), 114189, 114192, 114192.1, 11419

Compliance of this violation has been verified on: 11/08/2025

Minor Violations

Cited On: 11/08/2025

K21 - 3 Points - Hot and cold water not available; 113953(c), 114099.2(b), 114163(a), 114189, 114192, 114192.1, 11419

Inspector Observations: Water at the three compartment sink in the lower bar did not reach 120F.

[CA] An adequate, protected, pressurized, potable supply of hot water and cold water shall be provided at all times.

[SA] Facility to only use the upper bar and the kitchen until hot water is restored to the lower bar. Provide proof of corrections. A follow up inspection to occur.

Measured Observations

Item	Location	Measurement	Comments
Water	Three Compartment Sink - Kitchen	103.00 Fahrenheit	
Water	Handwash Sink - Upstairs Bar	102.40 Fahrenheit	
Water	Three Compartment Sink - Lower Bar	70.20 Fahrenheit	
Water	Handwash Sink - Kitchen	100.00 Fahrenheit	
Water	Handwash Sink - Restroom	100.00 Fahrenheit	

Overall Comments:

This is the first follow up inspection. This inspection was conducted outside of normal business hours and shall be charged. Invoice to follow.

Observations:

Facility has replaced the right water heater. The left water heater is still out of commission.

Original water heater: 75,100 BTU 100 gallons.

New Water Heater: 75,100 BTU 100 gallons.

Hot water has been restored to all plumbing fixtures of the facility. A singular water heater may not be sufficient to meet the minimum hot water demands for all plumbing fixtures. Ensure to repair hot water distribution system to the approved specs. Recommend limiting use of the dishwasher to lessen strain on hot water demand. District specialist to follow up with facility.

FACILITY RE-OPENED / PERMIT REINSTATED

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **11/22/2025**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

OFFICIAL INSPECTION REPORT

Facility FA0210360 - IMPROV	Site Address 62 S 2ND ST, SAN JOSE, CA 95113	Inspection Date 11/08/2025
Program PR0301115 - FOOD PREP / FOOD SVC OP 6-25 EMPLOYEES RC 2 - FP13	Owner Name SAN JOSE COMEDY CLUB LLC	Inspection Time 17:40 - 18:50

Legend:

[CA]	Corrective Action
[COS]	Corrected on Site
[N]	Needs Improvement
[NA]	Not Applicable
[NO]	Not Observed
[PBI]	Performance-based Inspection
[PHF]	Potentially Hazardous Food
[PIC]	Person in Charge
[PPM]	Part per Million
[S]	Satisfactory
[SA]	Suitable Alternative
[TPHC]	Time as a Public Health Control



Received By: David
Manager

Signed On: November 08, 2025