

County of Santa Clara

Department of Environmental Health

Consumer Protection Division

1555 Berger Drive, Suite 300, San Jose, CA 95112-2716

Phone (408) 918-3400 www.ehinfo.org



OFFICIAL INSPECTION REPORT

Facility FA0284467 - ROSS DRESS FOR LESS #1919	Site Address 1032 E BROKAW RD, SAN JOSE, CA 95131	Inspection Date 10/31/2024
Program PR0426656 - LIMITED FOOD SERVICE CAT 2 - FP76	Owner Name ROSS DRESS FOR LESS INC	Inspection Time 12:55 - 13:55
Inspected By MINDY NGUYEN	Inspection Type FOLLOW-UP INSPECTION	Consent By NADA

Placard Color & Score

GREEN
N/A

Comments and Observations

Major Violations

Cited On: 10/31/2024

K21 - 8 Points - Hot and cold water not available; 113953(c), 114099.2(b), 114163(a), 114189, 114192, 114192.1, 11419

Inspector Observations: Measured warm/hot water at restroom handwash sink and janitorial sink to be 71-74F.

[CA] Provide warm water (100F) at the handwash sinks and hot water (120F) at the janitorial sink.

[SA] Food sold by the facility is all prepackaged, non-PHF. A follow-up inspection will be conducted to confirm compliance.

Minor Violations

N/A

Measured Observations

Item	Location	Measurement	Comments
WARM/HOT WATER	RESTROOM HANDWASH SINK, JANITORIAL SINK	71.00 Fahrenheit	71-74F

Overall Comments:

This was a second follow up to the 10/14/24 and 10/23/24 inspections for the lack of hot water at the facility. Hot water measured at 71-74F at the restroom handwash sink and janitorial sink.

This inspection and subsequent follow-up inspection(s) will be billed \$298.00 each. Contact Mindy Nguyen at (408) 918-3490 when hot water is available to schedule the next follow-up inspection before Nov. 2024.

Notes:

- Consult Plan Check at (408) 918-3400 before replacing water heater with a different model or specifications.
- Inspector had received phone confirmation from Karen yesterday stating the water heater was repaired. Verify hot water is available before scheduling follow-up inspections.

When required to determine compliance, a single reinspection will be conducted without additional charge. If subsequent reinspections are required, an hourly fee (minimum one hour) at the current rate approved by the Board of Supervisors will be assessed for each and every reinspection until the necessary changes or corrections are made. Unless otherwise noted by the inspector, all violations are to be corrected no later than **11/14/2024**. Any major change in menu or any change in ownership must have prior approval by this Department. This may require structural and/or equipment changes or remodeling to accommodate new operations.

Legend:

[CA]	Corrective Action
[COS]	Corrected on Site
[N]	Needs Improvement
[NA]	Not Applicable
[NO]	Not Observed
[PBI]	Performance-based Inspection
[PHF]	Potentially Hazardous Food
[PIC]	Person in Charge
[PPM]	Part per Million
[S]	Satisfactory
[SA]	Suitable Alternative
[TPHC]	Time as a Public Health Control

Received By: Nada Shanawany

Area Supervisor

Signed On: October 31, 2024